

## 02.01a Fire safety risk assessment form

Date: 01/09/2023		Area: All						
Task/Hazard	Who Is At Risk	Safety Risk	Existing Control Measures	Likelihood	Severity	Score	New Control Measures Required	Revised Score*
FIRE	Staff Children Visitors	Injury caused by fire and/or smoke	Annually serviced fire extinguishers for all types of fire Extinguisher Servicability checked before each session Fire blanket available Fire evacuation notices Smoke detectors fitted and tested annually Fire drill practised termly Fire doors fitted Appropriate signage for exits Visitors informed of evacuation procedure Good housekeeping to prevent build up of potential 'fuel' Electrical PAT tested regularly Alarm trigger button fitted	2	2	4		
Manager Comments:  Reviewed annually				1- Never	1-Minor	1-5 Low	*Likelihood x Severity= Revised Score	
				2- Unlikely	2-3 Day Injury			
				3- Likely	3- Major Injury	6-12 Medium		
				4- Very Likely	4- Fatality			
				5- Certainty	5- Multiple Fatality	13-25 High		